

富士市新環境クリーンセンター 維持管理月報

令和7 年度 10 月

日付	曜日	天候	ごみ搬入量		ごみ投入量		焼却量残渣運搬量		灯油使用量	焼却稼働時間		燃焼室温度		燃焼炉出口温度2秒後		ボイラー出口温度		CO濃度		炉内圧力		触媒反応塔出口圧力		電力使用量	
			総搬入量	持込量	1号炉	2号炉	台数	重量	ごみ焼却	1号炉	2号炉	1号炉	2号炉	1号炉	2号炉	1号炉	2号炉	1号炉	2号炉	1号炉	2号炉	1号炉	2号炉	受電量	発電量
			kg	kg	kg	kg	台	kg	ℓ	時間	時間	℃	℃	℃	℃	℃	℃	ppm	ppm	kPa	kPa	kPa	kPa	kWh	kWh
1	水	雨	53.410	49.910	121.740				0	24.0		1020		932		164		3.3		-0.12		0.16		0	64,780
2	木	晴	208.700	63.730	38.820				1,442	12.7													10,940	20,590	
3	金	曇	220.920	68.430					0														12,760	0	
4	土	曇	37.060	37.060					0														11,100	0	
5	日	晴							0														6,850	0	
6	月	晴	290.380	81.880					0														11,530	0	
7	火	晴	265.060	57.920					0														11,260	0	
8	水	晴	59.370	50.810			1	9,910	0														11,010	0	
9	木	晴	200.310	56.460			2	28.480	0														12,620	0	
10	金	曇	212.160	55.520		80.290	3	37.450	4,156		15.0												10,180	34,260	
11	土	雨	31.530	29.750		121.700			0		24.0		1030		938		176		3.3		-0.10		0.11	0	71,380
12	日	曇				121.980			0		24.0		1029		928		167		2.8		-0.10		0.10	0	69,590
13	月	曇	300.320	92.380		121.900			0		24.0		1038		926		167		3.1		-0.11		0.10	0	71,310
14	火	曇	272.060	61.470		122.740			0		24.0		1045		921		167		2.8		-0.11		0.10	0	71,710
15	水	雨	63.780	55.030		123.330			0		24.0		1032		918		165		4.0		-0.10		0.08	0	68,110
16	木	雨	217.240	61.810		123.440	2	28.480	0		24.0		1031		907		165		4.0		-0.11		0.09	0	67,370
17	金	晴	227.960	77.430	68.920	123.970	1	17.990	3,883	14.8	24.0		1032		906		165		3.2		-0.10		0.08	0	102,370
18	土	晴	33.950	33.950	91.970	90.790			0	24.0	24.0	953	978	918	914	157	155	5.4	3.5	-0.10	-0.10	0.04	0.00	0	104,500
19	日	曇			88.990	89.730			0	24.0	24.0	938	968	922	911	150	153	4.6	4.7	-0.10	-0.10	0.03	0.00	0	96,460
20	月	曇	302.760	90.190	88.200	87.790	3	30.850	0	24.0	24.0	968	993	927	923	153	157	5.2	3.6	-0.10	-0.10	0.05	0.01	0	112,930
21	火	雨	277.610	67.760	89.960	88.100	2	19.960	0	24.0	24.0	959	980	909	913	152	153	5.4	4.5	-0.10	-0.10	0.03	0.00	0	100,380
22	水	雨	54.630	46.880	90.380	90.140	2	27.980	0	24.0	24.0	947	976	901	906	150	153	6.2	3.9	-0.10	-0.10	0.03	0.00	0	94,000
23	木	晴	195.310	59.230	89.030	88.540	2	27.370	0	24.0	24.0	960	982	902	907	151	154	3.8	2.4	-0.10	-0.10	0.06	0.01	0	95,800
24	金	曇	229.450	71.360	88.810	88.540	2	28.400	0	24.0	24.0	968	981	915	909	151	154	4.3	2.3	-0.11	-0.10	0.05	0.00	0	95,840
25	土	雨	29.350	29.350	89.070	88.860			0	24.0	24.0	958	978	919	909	151	153	4.8	2.2	-0.11	-0.10	0.06	0.01	0	92,270
26	日	雨			88.820	88.490			0	24.0	24.0	958	983	936	925	152	154	5.2	2.9	-0.10	-0.10	0.07	0.01	0	101,970
27	月	曇	295.030	96.020	89.790	88.910	2	27.840	0	24.0	24.0	962	998	929	927	153	156	4.3	2.9	-0.11	-0.10	0.07	0.01	0	110,940
28	火	晴	272.360	72.250	88.400	88.560	2	28.380	0	24.0	24.0	968	994	911	919	152	155	4.1	3.0	-0.10	-0.11	0.05	0.01	0	103,680
29	水	晴	60.060	57.110	90.360	90.080	2	27.500	0	24.0	24.0	958	977	909	909	151	154	5.4	2.9	-0.11	-0.10	0.04	0.00	0	94,030
30	木	晴	216.980	63.290	89.070	87.000	2	21.080	0	24.0	24.0	963	983	925	917	151	154	4.4	2.6	-0.10	-0.10	0.04	0.00	0	97,660
31	金	晴	241.350	76.260	89.470	90.830			0	24.0	24.0	965	992	918	920	152	155	4.1	2.9	-0.10	-0.11	0.05	0.01	0	102,600
合計			4,869.100	1,663.240	1,481.800	2,185.710	28	361.670	9,481	387.5	519.0													98,250	2,044,530
最大			302.760	96.020	121.740	123.970	3	37.450	4,156	24.0	24.0	1020	1045	936	938	164	176	6.2	4.7	-0.10	-0.10	0.16	0.11	12,760	112,930
最小			29.350	29.350	38.820	80.290	1	9,910	0	12.7	15.0	938	968	901	906	150	153	3.3	2.2	-0.12	-0.11	0.03	0.00	0	0
平均			180.337	61.601	87	99	2	26	305.8	22.8	23.6	963.0	1,000.0	918.2	916.8	152.7	158.7	4.7	3.2	-0.10	-0.10	0.06	0.03	3,169.4	65,952.6

熱灼減量(乾灰)	1号炉	0.7 %	10月20日 測定	2号炉	0.6 %	10月14日 測定
----------	-----	-------	-----------	-----	-------	-----------